

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50156930

Blatt Page
0001

Ihr Zeichen Client Reference
G.Q.

Unser Zeichen Our Reference
ZC10-KSH- 14703751 001

Ausstellungsdatum
01.07.2009

Date of Issue
(day/mo/yr)


Genehmigungsinhaber License Holder
ZHEJIANG MINGRONG ELECTRICAL
PROTECTION CO., LTD.
Wei 11th Road
Economic Developing Zone
Yueqing, Zhejiang 325600
P.R. China

Fertigungsstätte Manufacturing Plant
ZHEJIANG MINGRONG ELECTRICAL
PROTECTION CO., LTD.
Wei 11th Road
Economic Developing Zone
Yueqing, Zhejiang 325600
P.R. China

Prüfzeichen Test Mark

Geprüft nach Tested acc. to

EN 60269-1:2007
HD 60269-2:2007



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Sicherung (Low-voltage Fuse)

Type Designation : RT16-0 (NT0) 5
Fuse-link
Rated Voltage : 1) AC 500V 2) AC 690V 2
Rated Current : 1) 4A; 6A; 10A; 16A; 20A; 25A; 32A; 40A; 50A
63A; 80A; 100A; 125A; 160A
2) 4A; 6A; 10A; 16A; 20A; 25A; 32A; 40A; 50A
63A; 80A; 100A
Rated Breaking Capacity: 1) 100kA 2) 50kA
Rated Power Dissipation: <16W
Breaking Range : gG
Size : 0
Arc Voltage Limits : AC 2500V (peak value)
Fuse-base
Rated Voltage : AC 690V 1
Rated Power Acceptance : 25W
Rated Current : 160A
The labelling requirements acc. to EU Directive 2001/95 have
to be observed for distribution within the EEA.

8

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde und es bestätigt die Konformität des Produktes mit den oben genannten Standards und Prüfgrundlagen. Zusätzliche Anforderungen in Ländern, in denen das Produkt in Verkehr gebracht werden soll, müssen zusätzlich betrachtet werden. Die Herstellung des zertifizierten Produktes wird überwacht.
This certificate is based on our Testing and Certification Regulation and states the conformity of the product with the standards and testing requirements as indicated above. Any additional requirements in countries where the product is going to be marketed have to be considered additionally. The manufacturing of the certified product is subject to surveillance.

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Köln
Tel.: (+49/221) 8 06 - 13 71 e-mail: cert-validity@de.tuv.com
Fax: (+49/221) 8 06 - 39 35 http://www.tuv.com/safety

Zertifizierungsstelle

Dr.-Ing. T. Keiter

